

**Monmouth Ocean
Educational Services Commission
100 Tornillo Way
Tinton Falls, NJ 07712**

Analytical Results for Lead

**JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083**

Monmouth Ocean Educational Services Commission
 100 Tornillo Way, Tinton Falls
 Lead Results

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
1	N	21-5597.1	JRH Labs	15083	8/16/2021	06:11	200.9	8/24/2021	18:36	<2.00	2.00	1	N	
2	N	21-5597.2	JRH Labs	15083	8/16/2021	06:12	200.9	8/24/2021	18:43	<2.00	2.00	1	N	
3	N	21-5597.3	JRH Labs	15083	8/16/2021	06:15	200.9	8/24/2021	18:50	<2.00	2.00	1	N	
4	Y	21-5597.4	JRH Labs	15083	8/16/2021	06:32	200.9	8/24/2021	18:56	<2.00	2.00	1	N	
5	Y	21-5597.5	JRH Labs	15083	8/16/2021	06:34	200.9	8/24/2021	19:03	<2.00	2.00	1	N	

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

Monmouth Ocean Educational Services Commission
100 Tornillo Way
Tinton Falls, NJ 07712

Sample Date: 8-16-21

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME/CODE	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
21-5597.1	Field Blank	06:11	LEAD/1030	200.9	<2.00	8/24/2021	18:36	15
21-5597.2	TW-WC-3-Hall	06:12	LEAD/1030	200.9	<2.00	8/24/2021	18:43	15
21-5597.3	TW-WC-14-Hall	06:15	LEAD/1030	200.9	<2.00	8/24/2021	18:50	15
21-5597.4	TW-WC-3-Hall Flush	06:32	LEAD/1030	200.9	<2.00	8/24/2021	18:56	15
21-5597.5	TW-WC-14-Hall Flush	06:34	LEAD/1030	200.9	<2.00	8/24/2021	19:03	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 8-25-21

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION
LAB INFORMATION

Name: Monmouth Ocean Educational Services Commission
Address: 100 Tornillo Way
Client Rep: Kenneth Shine

Name: J.R. Henderson Labs
Address: 123 Seaman Ave, Beachwood, NJ
Proj. Mgr: Trevor Ellis

SCHOOL/PROJECT INFORMATION

BLDG ID: MOESC
BLDG No/Name: MOESC
BLDG Address: 100 Tornillo Way
Contact Name & Numbers: Ken Shine 908-*565-3997

(0) Yr. Built: 1999	(1) Yr. 1st Add.:	(2) Yr. 2nd Add.:	(3) Yr. 1st Mod.:	(4) Yr. 2nd Mod.:
-------------------------------	-------------------	-------------------	-------------------	-------------------

SAMPLING TEAM: Ken Shine
DATE OF SAMPLING: 8/16/21
SAMPLE DATA

Sample Description ID (ID must match container label)				Drinking Water Outlet Information				
Building Code:	Room / Fixture Code:	Fixture #:	Location:	Sampled Outlet Location/Coordinates/number	0 Seconds	30 Seconds	Time of collection (24hr)	
F e i l d	B l a n k	2			X		6:11am	
T W - W C - 3 -	H a l l				X		6:12am	
T W - W C - 1 4 -	H a l l				X		6:15am	
T W - W C - 3 -	H a l l		I - F l u s h		X		6:17am- 6:32am	15 Min Flush
T W - W C - 1 4 -	H a l l		I - F l u s h		X		6:19am- 6:34am	15 Min Flush

All containers are pre-cleaned/ 250 ml plastic bottles preserved w HNO₃ @ pH<2 by field__ or to be preserved by lab X

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:
<u>[Signature]</u>	<u>[Signature]</u>	<u>11:15 8/17/21</u>
II.		
III.		

Method of shipment/delivery: Fed-Ex X Hand Delivery US Mail UPS Courier Other:

INSTRUCTIONS TO THE LABORATORY

<input checked="" type="checkbox"/> Analyze both initial and follow up samples ___ Other:	Lab: J.R.Henderson Labs 732-341-1211 Contact: Stacey Yuro	Report Results to: <input checked="" type="checkbox"/> Phone 908-565-3997 <input checked="" type="checkbox"/> Email: kshine@moesc.org ___ Fax
Comments: Provide Laboratory Data Report (LDR) Package and Chain of Custody		